

# Information (12:00), July 10, 2024

To All Missions (Embassies, Consulates and International Organizations in Japan)

## Report on the discharge record and the seawater monitoring results at Fukushima Daiichi Nuclear Power Station during May

The Ministry of Foreign Affairs wishes to provide all international Missions in Japan with a report on the discharge record and seawater monitoring results with regard to groundwater pumped from the sub-drain and groundwater drain systems, as well as bypassing groundwater pumped during the month of May at Fukushima Daiichi Nuclear Power Station (NPS).

### 1. Summary of decommissioning and contaminated water management

In May the summary of monthly progress on decommissioning and contaminated water management of Fukushima Daiichi NPS was issued shown in Appendix 1. For more information, please see the following URL: <https://www.meti.go.jp/english/earthquake/nuclear/decommissioning/pdf/mp202405.pdf>

### 2. Sub-drain and Groundwater Drain Systems

In May purified groundwater pumped from the sub-drain and groundwater drain systems was discharged on the dates shown in Appendix 2. Prior to every discharge, an analysis on the quality of the purified groundwater to be discharged was conducted by Tokyo Electric Power Company (TEPCO) and the results were announced.

All the test results during the month of May have confirmed that the radiation levels of sampled water were substantially below the operational targets set by TEPCO (these operational targets are well below the density limit specified by the Reactor Regulation). The results of these analyses were also confirmed by third-party organization (Tohoku Ryokka Kankyohozen Co.).

In addition, TEPCO and Japan Atomic Energy Agency (JAEA), at the request of the Government of Japan, regularly conduct more detailed analyses on the purified groundwater. The results of JAEA's latest analyses confirmed that TEPCO's analyses were accurate and verified that the radiation levels of sampled groundwater was substantially below the operational target (see Appendix 3).

Moreover, TEPCO publishes the results of analyses conducted on seawater

sampled during the discharge operation at the nearest seawater sampling post from the discharge point (see Appendix 4). The results show that the radiation levels of seawater remain lower than the density limit specified by the Reactor Regulation and significant change in the radioactivity has not been observed.

### 3. Groundwater Bypassing

In May, the pumped bypassing groundwater was discharged on the dates shown in Appendix 5. Prior to every discharge, an analysis on the quality of the groundwater to be discharged was conducted by TEPCO and the results were announced.

All the test results during the month of May have confirmed that the radiation levels of sampled water were substantially below the operational targets set by TEPCO (these operational targets are well below the density limit specified by the Reactor Regulation). The results of these analyses were also confirmed by Japan Chemical Analysis Center.

In addition, TEPCO and JAEA, at the request of the Government of Japan, regularly conduct more detailed analyses on the groundwater. The results of JAEA's latest analyses confirmed that TEPCO's analyses were accurate and verified that the radiation levels of the sampled groundwater were substantially below the operational target (see Appendix 6).

Moreover, TEPCO publishes analysis results on seawater sampled during the discharge operation at the nearest seawater sampling post from the discharge point (see Appendix 7). The result shows that the radiation levels in seawater remain lower than the density limit specified by the Reactor Regulation and significant change in the radioactivity has not been observed. The analysis had been conducted once a month until March 2017. Since April 2017, it is conducted four times a year because there has been no significant fluctuation in the concentration of radioactive materials in the sea water, and no influence on the surrounding environment has been confirmed.

The sampling process for analyses conducted this month is the same as the one conducted in the information disseminated last month. Results of the analyses are shown in the attached appendices:

(For further information, please contact TEPCO at (Tel: 03-6373-1111) or refer to the TEPCO's website:

<http://www.tepco.co.jp/en/nu/fukushima-np/handouts/index-e.html>)

Contact: International Nuclear Energy Cooperation Division,  
Ministry of Foreign Affairs, Tel 03-5501-8227





# Progress Status and Future Challenges of the Mid-and-Long-Term Roadmap toward Decommissioning of TEPCO Holdings Fukushima Daiichi Nuclear Power Station (Outline)

## Progress status

- The temperatures of the Reactor and the Primary Containment Vessel of Units 1-3 have been maintained stable. There was no significant change in the concentration of radioactive materials newly released from Reactor Buildings into the air. It was concluded that the comprehensive cold shutdown condition had been maintained.

### Discharge of ALPS treated water into the sea

In preparation for the 2nd discharge of ALPS treated water in FY2024, Tank Group A of the measurement/confirmation facility was analyzed and TEPCO and an external institute confirmed that the analytical results satisfied the discharge requirement.

Following the confirmation, discharge of ALPS treated water of Tank Group C of the measurement/confirmation facility into the sea commenced from May 17.

Regarding tritium in seawater, TEPCO will continue to confirm that discharge is conducted safely as planned while satisfying the discharge requirement through the results of daily quick analyses conducted by TEPCO and others.

< Measurement status of the 2nd discharge of ALPS treated water in FY2024 >  
 \* Detailed information described on the right on Page 5


Measurement status	Compliance with requirement
[TEPCO] Attributes of the treated water from Tank Group C (Concentration of the 29 types of radionuclides within the measurement / evaluation scope and regulatory requirements) (Sampled on March 25)	○
[TEPCO] Downstream of discharge shaft and seawater pipe header (Sampled on May 28)	○
[TEPCO] Results of sea area monitoring at 8 points within 3km of the Power Station (Sampled on May 28)	○
[Fisheries Agency] Tritium concentration in marine products (Flounder and others, sampled on May 24)	○
[Fukushima Prefecture] Tritium concentration in seawater off the coast of Fukushima Prefecture (9 points, sampled on May 20)	○

### Unit 2 Status of preparation for fuel debris trial retrieval

Removal of deposit in the penetration (X-6 penetration) having been conducted since January 10 was completed on May 13 and it was confirmed that there would be no impact on the passage of telescopic-type equipment and the robot arm through X-6 penetration.

Subsequently, installation of the connection structure and pipe to X-6 penetration is underway.

Based on present estimates, trial retrieval will commence in around August to October 2024.




Reactor Building (R/B) Unit 1

### Unit 1 Progress of work toward spent fuel removal

At Unit 1 Reactor Building, removal of overflowing rubble from the south side external wall was completed on April 25. No significant variation was confirmed in the dust concentration during removal work.

Except for the south side and a portion of the west side neighboring the south side, installation of the lower structure was completed. At present, anchor drilling is underway and base plates are being installed sequentially.




Unit 2

### Unit 3 Progress of the investigation inside the Reactor Building


Regarding information on space (accessibility and others) and dose rate of Unit 3 inside the Reactor Building (R/B), an investigation is underway from April 16 to around mid-June. This investigation is conducted for the R/B southwest area and a remote control robot is being used to acquire video, point cloud and dose rate data.

The investigation will continue and based on the information acquired, radiation sources in the area will be identified and the dose rate distribution estimated. The information will be utilized in future examinations on decommissioning and formulating investigation plans elsewhere.



\* This spherical image was acquired in a 360° direction, then synthesized on the plane. Accordingly, there are bidirectional distortions like a fisheye lens.

Photos taken on April 16 2024  
 Y-Hiager measurement on April 17 2024



Unit 3

**Removed fuel (assemblies) 1535/1535 \*1**  
 (Fuel removal completed on December 22, 2014)



Unit 4 \*1 Including two new fuel assemblies removed first in 2012.

### Implementation status of operational safety inspection

Given the troubles that occurred last year, such as bodily contamination of workers, water leaking from the high-temperature incinerator building and the suspension of the on-site electric power system, TEPCO is implementing operational safety inspections for all work from May. As well as striving to prevent any recurrence of these troubles, work safety in the power station needs to be enhanced throughout. After reviewing the field conditions, the risk factors in the field are extracted and work shall recommence as each of the reviews are completed.

Matters to be improved, noted and other aspects detected during the inspection will be reflected appropriately, while continuing such efforts. By accumulating each of the improvements, TEPCO will thoroughly ensure the safety of the surrounding environment and all those engaged in decommissioning work.

Results of analyses on the quality of the purified groundwater pumped from the sub-drain and groundwater drain systems at Fukushima Daiichi NPS (made available by TEPCO prior to discharge)

(Unit: Bq/L)

Date of sampling *Date of discharge	Detected nuclides	Analytical body	
		TEPCO	Third-party organization
May 27 <sup>th</sup> , 2024  *Discharged on June 1 <sup>st</sup>	Cs-134	ND (0.73)	ND (0.55)
	Cs-137	ND (0.72)	ND (0.71)
	Gross $\beta$	ND (1.9)	ND (0.32)
	H-3	730	760
May 26 <sup>th</sup> , 2024  *Discharged on May 31 <sup>st</sup>	Cs-134	ND (0.57)	ND (0.50)
	Cs-137	ND (0.60)	ND (0.73)
	Gross $\beta$	ND (1.8)	ND (0.30)
	H-3	760	770
May 25 <sup>th</sup> , 2024  *Discharged on May 30 <sup>th</sup>	Cs-134	ND (0.69)	ND (0.58)
	Cs-137	ND (0.57)	ND (0.56)
	Gross $\beta$	ND (2.0)	ND (0.33)
	H-3	700	790
May 24 <sup>th</sup> , 2024  *Discharged on May 29 <sup>th</sup>	Cs-134	ND (0.68)	ND (0.62)
	Cs-137	ND (0.63)	ND (0.63)
	Gross $\beta$	ND (0.62)	ND (0.32)
	H-3	720	740
May 23 <sup>rd</sup> , 2024  *Discharged on May 28 <sup>th</sup>	Cs-134	ND (0.89)	ND (0.55)
	Cs-137	ND (0.72)	ND (0.83)
	Gross $\beta$	ND (2.0)	ND (0.37)
	H-3	690	720
May 22 <sup>nd</sup> , 2024  *Discharged on May 27 <sup>th</sup>	Cs-134	ND (0.88)	ND (0.64)
	Cs-137	ND (0.90)	ND (0.51)
	Gross $\beta$	ND (1.8)	ND (0.38)
	H-3	680	700
May 21 <sup>st</sup> , 2024  *Discharged on May 26 <sup>th</sup>	Cs-134	ND (0.75)	ND (0.50)
	Cs-137	ND (0.61)	ND (0.66)
	Gross $\beta$	ND (1.9)	ND (0.39)
	H-3	650	690
May 20 <sup>th</sup> , 2024  *Discharged on May 25 <sup>th</sup>	Cs-134	ND (0.88)	ND (0.65)
	Cs-137	ND (0.82)	ND (0.52)
	Gross $\beta$	ND (2.0)	0.38

	H-3	680	720
May 19 <sup>th</sup> , 2024  *Discharged on May 24 <sup>th</sup>	Cs-134	ND (0.93)	ND (0.50)
	Cs-137	ND (0.63)	ND (0.56)
	Gross $\beta$	ND (1.9)	ND (0.36)
	H-3	620	670
May 18 <sup>th</sup> , 2024  *Discharged on May 23 <sup>rd</sup>	Cs-134	ND (0.71)	ND (0.69)
	Cs-137	ND (0.65)	ND (0.73)
	Gross $\beta$	ND (2.0)	ND (0.33)
	H-3	670	700
May 17 <sup>th</sup> , 2024  *Discharged on May 22 <sup>nd</sup>	Cs-134	ND (0.69)	ND (0.79)
	Cs-137	ND (0.61)	ND (0.60)
	Gross $\beta$	ND (0.63)	ND (0.33)
	H-3	580	640
May 16 <sup>th</sup> , 2024  *Discharged on May 21 <sup>st</sup>	Cs-134	ND (0.68)	ND (0.64)
	Cs-137	ND (0.86)	ND (0.61)
	Gross $\beta$	ND (1.9)	ND (0.35)
	H-3	640	690
May 15 <sup>th</sup> , 2024  *Discharged on May 20 <sup>th</sup>	Cs-134	ND (0.77)	ND (0.64)
	Cs-137	ND (0.54)	ND (0.61)
	Gross $\beta$	ND (1.7)	ND (0.33)
	H-3	640	680
May 14 <sup>th</sup> , 2024  *Discharged on May 19 <sup>th</sup>	Cs-134	ND (0.56)	ND (0.76)
	Cs-137	ND (0.55)	ND (0.61)
	Gross $\beta$	ND (1.8)	ND (0.37)
	H-3	650	680
May 13 <sup>th</sup> , 2024  *Discharged on May 18 <sup>th</sup>	Cs-134	ND (0.81)	ND (0.61)
	Cs-137	ND (0.71)	ND (0.69)
	Gross $\beta$	ND (1.9)	ND (0.36)
	H-3	650	670
May 12 <sup>th</sup> , 2024  *Discharged on May 17 <sup>th</sup>	Cs-134	ND (0.71)	ND (0.80)
	Cs-137	ND (0.66)	ND (0.78)
	Gross $\beta$	ND (1.7)	ND (0.34)
	H-3	600	620
May 11 <sup>th</sup> , 2024  *Discharged on May 16 <sup>th</sup>	Cs-134	ND (0.84)	ND (0.69)
	Cs-137	ND (0.73)	ND (0.51)
	Gross $\beta$	ND (1.7)	ND (0.34)
	H-3	580	620
May 9 <sup>th</sup> , 2024  *Discharged on May 14 <sup>th</sup>	Cs-134	ND (0.84)	ND (0.75)
	Cs-137	ND (0.54)	ND (0.70)
	Gross $\beta$	ND (0.71)	0.39
	H-3	600	630
May 8 <sup>th</sup> , 2024	Cs-134	ND (0.75)	ND (0.60)

*Discharged on May 13 <sup>th</sup>	Cs-137	ND (0.78)	ND (0.71)
	Gross $\beta$	ND (2.1)	ND (0.34)
	H-3	660	680
May 7 <sup>th</sup> , 2024  *Discharged on May 12 <sup>nd</sup>	Cs-134	ND (0.71)	ND (0.50)
	Cs-137	ND (0.74)	ND (0.71)
	Gross $\beta$	ND (1.8)	ND (0.37)
	H-3	650	670
May 6 <sup>th</sup> , 2024  *Discharged on May 11 <sup>th</sup>	Cs-134	ND (0.64)	ND (0.60)
	Cs-137	ND (0.65)	ND (0.61)
	Gross $\beta$	ND (1.8)	ND (0.38)
	H-3	630	690
May 5 <sup>th</sup> , 2024  *Discharged on May 10 <sup>th</sup>	Cs-134	ND (0.77)	ND (0.76)
	Cs-137	ND (0.74)	ND (0.58)
	Gross $\beta$	ND (1.9)	ND (0.37)
	H-3	680	710
May 4 <sup>th</sup> , 2024  *Discharged on May 9 <sup>th</sup>	Cs-134	ND (0.84)	ND (0.65)
	Cs-137	ND (0.79)	ND (0.71)
	Gross $\beta$	ND (2.0)	0.36
	H-3	670	710
May 3 <sup>rd</sup> , 2024  *Discharged on May 8 <sup>th</sup>	Cs-134	ND (0.72)	ND (0.62)
	Cs-137	ND (0.76)	ND (0.66)
	Gross $\beta$	ND (1.8)	ND (0.36)
	H-3	710	730
May 2 <sup>nd</sup> , 2024  *Discharged on May 7 <sup>th</sup>	Cs-134	ND (0.79)	ND (0.77)
	Cs-137	ND (0.51)	ND (0.63)
	Gross $\beta$	ND (1.9)	ND (0.32)
	H-3	740	780
May 1 <sup>st</sup> , 2024  *Discharged on May 6 <sup>th</sup>	Cs-134	ND (0.72)	ND (0.48)
	Cs-137	ND (0.54)	ND (0.63)
	Gross $\beta$	ND (0.58)	ND (0.36)
	H-3	720	750
April 30 <sup>th</sup> , 2024  *Discharged on May 5 <sup>th</sup>	Cs-134	ND (0.65)	ND (0.62)
	Cs-137	ND (0.76)	ND (0.58)
	Gross $\beta$	ND (1.8)	ND (0.33)
	H-3	730	710
April 29 <sup>th</sup> , 2024  *Discharged on May 4 <sup>th</sup>	Cs-134	ND (0.68)	ND (0.60)
	Cs-137	ND (0.83)	ND (0.71)
	Gross $\beta$	ND (1.7)	0.43
	H-3	820	860
April 28 <sup>th</sup> , 2024  *Discharged on May 3 <sup>rd</sup>	Cs-134	ND (0.81)	ND (0.60)
	Cs-137	ND (0.64)	ND (0.78)
	Gross $\beta$	ND (1.7)	ND (0.33)
	H-3	800	820
April 27 <sup>th</sup> , 2024	Cs-134	ND (0.76)	ND (0.61)

*Discharged on May 2 <sup>nd</sup>	Cs-137	ND (0.72)	ND (0.60)
	Gross $\beta$	ND (1.7)	ND (0.37)
	H-3	790	830

- \* \* ND: represents a value below the detection limit; values in ( ) represent the detection limit.
- \* In order to ensure the results, third-party organizations have also conducted an analysis and verified the radiation level of the sampled water.
- \* Third-party organization : Tohoku Ryokka Kankyohozen Co., Ltd



Result of detailed analyses conducted by TEPCO, JAEA, and Japan Chemical Analysis Center (In order to confirm the validity of analysis, the Government of Japan also requests JAEA; and TEPCO requests Japan Chemical Analysis Center to conduct independent analyses)

(Unit: Bq/L)

Date of sampling	Detected nuclides	Analytical body		
		JAEA	TEPCO	Japan Chemical Analysis Center
April 1 <sup>st</sup> ,2024	Cs-134	ND (0.0030)	ND (0.0047)	ND (0.0057)
	Cs-137	0.0063	0.0096	0.0059
	Gross $\alpha$	ND (0.47)	ND (2.0)	ND (2.3)
	Gross $\beta$	ND (0.48)	ND (0.60)	ND (0.52)
	H-3	440	440	450
	Sr-90	0.0015	ND (0.0014)	ND (0.0061)

\* ND: represents a value below the detection limit; values in ( ) represent the detection limit.

(Reference)

(Unit: Bq/L)

Radionuclides	Operational Targets	Density Limit specified by the Reactor Regulation	World Health Organization (WHO) Guidelines for Drinking Water Quality
Cs-134	1	60	10
Cs-137	1	90	10
Gross $\alpha$	—	—	—
Gross $\beta$	3 (1) ※	—	—
H-3	1,500	60,000	10,000
Sr-90	—	30	10

※ The operational target of Gross  $\beta$  is 1 Bq/L in the survey which is conducted once every ten days.

※ The reference table shows the values of operational targets before discharge. Since the values after discharge contain natural radioactive materials in seawater, there will be differences between the values and the operational targets values.

Results of analysis on the seawater sampled near the discharge point (North side of Units 5 and 6 discharge channel)

(Unit: Bq/L)

Date of sampling	Detected nuclides	Sampling point (South discharge channel)
March 25 <sup>th</sup> , 2024  *Sampled before discharge of purified groundwater.	Cs-134	ND (0.75)
	Cs-137	ND (0.86)
	Gross $\beta$	9.5
	H-3	ND (0.31)

Results of analyses on the water quality of the groundwater pumped up for bypassing at Fukushima Daiichi NPS (made available by TEPCO prior to discharge)

(Unit: Bq/L)

Date of sampling *Date of discharge	Detected nuclides	Analytical body	
		TEPCO	Third-party organization
May 24 <sup>th</sup> , 2024  *Discharged on May 29 <sup>th</sup>	Cs-134	ND (0.68)	ND (0.71)
	Cs-137	ND (0.74)	ND (0.73)
	Gross $\beta$	ND (0.59)	ND (0.33)
	H-3	46	48
May 17 <sup>th</sup> , 2024  *Discharged on May 22 <sup>nd</sup>	Cs-134	ND (0.81)	ND (0.54)
	Cs-137	ND (0.55)	ND (0.60)
	Gross $\beta$	ND (0.65)	ND (0.30)
	H-3	40	46
May 10 <sup>th</sup> , 2024  *Discharged on May 15 <sup>th</sup>	Cs-134	ND (0.69)	ND (0.69)
	Cs-137	ND (0.61)	ND (0.69)
	Gross $\beta$	ND (0.56)	ND (0.32)
	H-3	46	48
May 3 <sup>rd</sup> , 2024  *Discharged on May 8 <sup>th</sup>	Cs-134	ND (0.87)	ND (0.73)
	Cs-137	ND (0.79)	ND (0.83)
	Gross $\beta$	ND (0.69)	ND (0.32)
	H-3	42	47

- \* \* ND: represents a value below the detection limit; values in ( ) represent the detection limit
- \* In order to ensure the results, third-party organizations have also conducted an analysis and verified the radiation level of the sampled water.
- \* Third-party organization: Tohoku Ryokka Kankyohozen Co., Ltd

Result of detailed analyses conducted by TEPCO, JAEA, and Japan Chemical Analysis Center (In order to confirm the validity of analysis, the Government of Japan also requests JAEA; and TEPCO requests Japan Chemical Analysis Center to conduct independent analyses)

(Unit: Bq/L)

Date of sampling	Detected nuclides	Analytical body		
		JAEA	TEPCO	Japan Chemical Analysis Center
April 5 <sup>th</sup> , 2024	Cs-134	ND (0.0024)	ND (0.0045)	ND (0.0061)
	Cs-137	ND (0.0021)	ND (0.0042)	ND (0.0043)
	Gross $\alpha$	ND (0.51)	ND (2.0)	ND (2.3)
	Gross $\beta$	ND (0.48)	ND (0.64)	ND (0.60)
	H-3	43	42	43
	Sr-90	ND (0.0015)	ND (0.0013)	ND (0.0062)

\* ND: represents a value below the detection limit; values in ( ) represent the detection limit.

(Reference)

(Unit: Bq/L)

Radionuclides	Operational Targets	Density Limit specified by the Reactor Regulation	World Health Organization (WHO) Guidelines for Drinking Water Quality
Cs-134	1	60	10
Cs-137	1	90	10
Gross $\alpha$	—	—	—
Gross $\beta$	5 (1) ※	—	—
H-3	1,500	60,000	10,000
Sr-90	—	30	10

※ The operational target of Gross  $\beta$  is 1 Bq/L in the survey which is conducted once every ten days.

※ The reference table shows the values of operational targets before discharge. Since the values after discharge contain natural radioactive materials in seawater, there will be differences between the values and the operational targets values.

## Results of analyses on the seawater sampled near the discharge point (Around South Discharge Channel)

(Unit: Bq/L)

Date of sampling ※conducted four times a year	Detected nuclides	Sampling point (South discharge channel)
March 22 <sup>nd</sup> , 2024	Cs-134	ND (0.86)
	Cs-137	ND (0.47)
	Gross $\beta$	13
	H-3	0.54